

ROCKY FLATS ENVIRONMENTAL TECHNOLOGY SITE REGULATORY CONTACT RECORD

Date/Time: May 27, 2004
Site Contact(s): Dyan Foss
Phone: (303) 966-7577
Regulatory Contact: David Kruchek
Phone: (303) 692-3328
Agency: CDPHE

Purpose of Contact: Building 881, Room 11, Old Process Waste Line Pipe penetration

Discussion

This contact record is to document the consultative process and CDPHE approval of the disposition of a piece of old process waste line that penetrates into Room 11 in Building 881. Room 11 is the lowest level of Building 881 and is currently below grade. During the demolition of Building 881, this area will have already been backfilled. After the restoration of the B881 area to final grade, Room 11 will be approximately 15 to 20 feet below grade.

In Room 11, there is a penetration through the wall to the exterior soil that contains a piece of old process waste line. This pipe does not actually run through Room 11, but actually runs through the soil between the inner basement wall and the outer building wall, and was cut off outside B881 and plugged with epoxy. Since the pipe is currently located in the soil approximately 10 feet below current grade, will be 15 to 20 feet below final grade, and has contamination of 600 dpm; it was determined that excavation of this OPWL from between the building walls was not necessary, but that plugging the interior end of the pipe with at least a foot of grout would be sufficient prior to backfilling the room. In addition, the pipe and its location will be annotated in the B881 Closeout Report.

Contact Record Prepared By: Dyan Foss

Required Distribution:


M. Aguilar, USEPA
S. Bell, DOE-RFPO
B. Birk, DOE-RFPO
C. Deck, K-H Legal
D. Foss, K-H 707/776/777
C. Gilbreath, K-H 771/774
S. Gunderson, CDPHE
G. Kleeman, USEPA
J. Legare, DOE-RFPO

Contact Record 4/10/00
Rev. 3/25/04

R. Leitner, K-H 371/374
J. Mead, K-H ESS
G. Morgan, DOE-RFPO
S. Nesta, K-H RISS
K. North, K-H ESS/MS
R. Schassburger, DOE-RFPO
D. Shelton, K-H ESS
C. Zahm, K-H Legal

Additional Distribution:

Mike Swartz
Don Clark
Justin Ward
Gary Morgan



ADMIN RECORD